



Date: October 3, 2017

Memo: Lostant School Lead Water Test Results


To: Parents of Lostant School Students

On January 16, 2017, Governor Bruce Rauner signed Senate Bill 0550 that requires all schools that serve pre-kindergarten through 5th grade students to test for lead in water that is used for drinking and cooking for schools built before January 1, 2000. Sampling must be completed by December 31, 2017. Parents must be notified of the test results. Below are the results for Lostant School.

1. Two water samples from all drinking fountains and the kitchen sink were collected on September 19, 2017.
2. Test, Inc. located in Peru, Illinois received the samples on September 20, 2017 for testing purposes.
3. The threshold limit is 5 ppb.
4. Four of the five water fountains and the kitchen sink reflected lead detection limits under 5 ppb.
5. The water fountain located in the gym lobby reflected lead detection limits over 5 ppb. The first sample was 5.28 ppb and the second sample was 5.64 ppb.

If you are concerned about your child's health, it is advised to contact your health care provider. You may visit the USEPA website at <https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water> for information about lead in drinking water.

Educationally yours,



Dr. Malahy
Superintendent